

CERTIFICATE OF COMPLIANCE

Certificate Number 20190402-EX1394
Report Reference EX1394-19570218
Issue Date 2019-APRIL-02

Issued to: ELKHART BRASS MFG CO INC
1302 W BEARDSLEY AVE
PO BOX 1127
ELKHART IN 46515-1127

This certificate confirms that representative samples of NOZZLES, SPRAY HOSE, PORTABLE
See Addendum Page for Models

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 401, Portable Spray Hose Nozzles for Fire-Protection Service

Additional Information: See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20190402-EX1394
Report Reference EX1394-19570218
Issue Date 2019-APRIL-02

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

USL - Basic Spray Nozzle -

Model No.	Fire Types	Size In.	Maximum Inlet Pressure, psig	Rated Operating Pressure psig	Rated Flow at Rated Operating Pressure, gpm	Flow in Wide Open Position at 100 psig, gpm
L-205-B95	Class A and B	1-1/2	200	100	95	95
L-205-B125	Class A and B	1-1/2	200	100	125	125
L-205-EB95	Class A, B, and C	1-1/2	200	100	95	95

USL, CNL - Basic Spray Nozzle -

Model No.	Fire Types	Size In.	Maximum Inlet Pressure, psig	Rated Operating Pressure psig	Rated Flow at Rated Operating Pressure, gpm	Flow in Wide Open Position at 100 psig, gpm
L-206T	Class A and B	1-1/2	175	100	115	115
L-205-EB125	Class A, B and C	1-1/2	175	100	125	125
D-205-B1	Class A and B	2-1/2	175	100	186	186
D-205-B	Class A and B	2-1/2	175	100	280	280



Bruce Mahrenholz, Director North American Certification Program
 UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

