

Certificate of Compliance

Master Stream Nozzles for use with Monitors

This certificate is issued for the following equipment:

Model C-J-B. Fixed gallonage type, 350 and 500 gal/min (1325 and 1893 L/min) with a rated service pressure of 200 psi (13.8 bar) for use with 2-1/2 in. (65 mm) nominal size fixed monitors.

Model CJ-B-RC. Remote cable controlled fixed gallonage type, 350 and 500 gal/min (1325 and 1893 L/min) with a rated service pressure of 200 psi (13.8 bar) for use with 2-1/2 in. (65 mm) nominal size fixed monitors

Approved for:

Elkhart Brass Mfg. Co., Inc.
1302 West Beardsley Avenue
Elkhart, IN 46515

FM Approvals confirms that the items have been found to comply with the following standard:

FM Approvals Standard 5511

Project Identifier: 3025094

Date of Approval: September 11, 2007



Member of the FM Global Group

A handwritten signature in black ink, appearing to read "Richard B. Dunne", written over a horizontal line.

Richard B. Dunne,
Manager - Hydraulics Group

April 22, 2008

Date