



Certificate of Compliance

MASTER STREAM NOZZLES FOR USE WITH MONITORS

This certificate is issued for the following:

Model	Nozzle Type	Discharge gal/min (L/min)	Operating Pressure psi (bar)	Hose Thread	Material
IMS 750	Constant Gallorage	750 (2839)	100 (6.9)	2.5" NHT	Brass
IMS 1000	Constant Gallorage	1000 (3785)	100 (6.9)	2.5" NHT	Brass
SM 1250B	Constant Pressure	1250 (4732)	75 (5.2)	2.5" NHT, 3.5" NHT	Brass
SM 2000B	Constant Pressure	2000 (7570)	80 (5.5)	3.5" NHT	Brass

Prepared for:

ELKHART BRASS MFG. CO., INC
1302 WEST BEARDSLEY AVENUE
ELKHART, IN 46515

FM Approvals confirms that the products above have been found to comply with the following standards:

FM Approvals Class 5511 – Approval Standard for Firefighting Nozzles For Use With Hose, Monitor Assemblies, And Other Firefighting Equipment, June 2007

Approval Identification: 3036793

Original Approval Granted: September 10, 2010
Reissued Date: October 26, 2010

Said Approval is subject to satisfactory field performance, continuing follow-up Facilities and Procedures Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

For more than 160 years FM Approvals has partnered with business and industry to reduce property losses.



Member of the FM Global Group

A handwritten signature in dark ink, appearing to read 'Richard B. Dunne'.

Richard B. Dunne
Group Manager- Hydraulics
FM Approvals
1151 Boston Providence Turnpike
Norwood, MA 02062

10/26/10

Date